State of North Carolina Department of Environment, Health and Natural Resources Winston-Salem Regional Office

James B. Hunt, Jr., Governor Jonathan B. Howes, Secretary



March 25, 1996

<u>CERTIFIED MAIL NUMBER: P-536 317 035</u> RETURN RECEIPT REQUESTED

NC-Division of Forest Resources P.O. Box 27687 Raleigh, NC 27611

SUBJECT:

Underground Storage Tank (UST) Closure Assessment at N.C. Forest

Resources, Route 16, Box 272 (Hargrave Road), Lexington, Davidson County,

Incident Number Unassigned

Dear Sir or Madam:

The Groundwater Section of the Winston-Salem Regional Office is now reviewing the UST closure assessment for the subject location. In order to determine whether or not the closure was performed in accordance with State and Federal regulations, the Groundwater Section must be provided with the following information 30 days from receipt of this letter:

- o unless the tank excavation extended to all areas of the dispenser locations, samples are needed under associated dispensers -- one sample beneath each coupling joint location (swing joint, flexible connector) and one additional sample for every ten feet of island; and,
- o refer to the enclosed chart(s) for analyses that are required to be run and were not for the original closure report, please resample as needed.

Your cooperation is appreciated. Providing the requested information by the deadline specified in this letter will prevent a Notice of Violation being issued to you for the failure to

provide an adequate closure report. 585 Waughtown Street Winston-Salem, North Carolina 27107-2241 Voice 910-771-4600



FAX 910-771-4632 An Equal Opportunity/Affirmative Action Employer 50% recycled/10% post-consumer paper All soil sample analyses must be accompanied by a chain-of-custody and the sampling protocol. Please note that all subsurface investigative work is now required to be supervised by a Licensed Geologist or Professional Engineer, with all reports signed and sealed by that professional. Please refer to the file name, N.C. Forest Resources, on the cover letter of your reply. This will help us speed up the review. If you have any questions, please contact me at the letterhead address and/or telephone number.

Sincerely,

Chornes Moore

Thomas Moore Hydrogeological Technician

Regional Office Files cc: P-536 317 035 (Saa Flavarsa Santio Bired; and No. need anothical data , State and IfP Code Need I sample underneith each dispenser 3 isa Fee need to cur 5030 (54946-3350) bial Delivery Fee 43 Diesel USF #2 - Gasoline rricted Delivery: Fee 5-4- 54848 5-7 (5030/54846) im Receipt showing hom and Date Delivered 5-3 - 5-846 5-6 (5050) sm Receipt showing to whom a land Address of Col Very 5-5-(5030) Will Postage and Faesi Imask or Date